

PIG® Build-A-Berm® Barrier Bladder Section

#PLR517 - 7.25" x 44" x 4"



Add this special bladder section to your 4" Build-A-Berm system for additional containment capacity - without increasing your footprint or wall height.

- Bladder expands to provide 55 gallons of containment in addition to the capacity of your 4"H Build-A-Berm system
- Helps you meet containment regs without increasing the footprint or wall height of your barrier system (bladder deployment requires an area of 66" x 58")
- Build new or retrofit your existing 4"H Build-A-Berm system; secure to floor with Sili-Thane sealant (PTY340), then seal seams with Industrial-Strength Vinyl Cement (PTY105)
- Durable, 18 oz. all-vinyl covering resists oils, coolants and most chemicals
- Black color identifies bladder section between standard yellow sections
- Clearly labeled to remind workers not to walk on, drive over or block flap where bladder deploys
- Easy removal requires only a flat-bladed shovel
- Great for use around leak-prone areas where you can't expand the Build-A-Berm footprint into aisles



New Pig

By Phone:
1-855-493-HOGS

Online:
newpig.com

Email:
hothogs@newpig.com

One Pork Avenue • Tipton PA 16684-0304

© 2014 New Pig Corporation. All rights reserved.
PIG and the PIG logo are trademarks in the U.S. and other countries.

ITEM: PLR517 - Pg 1 of 2

PLR517 Specifications

Style:	Non-Weight Bearing
Color:	Black
Dimensions:	7.25" W x 44" L x 4" H
Bladder Dimensions	66" L x 58" W
Deployed:	
Bladder Volume:	55-gal.
Intended For:	Smooth Surface
Temperature Limit:	-22 °F to 160 °F
Sold as:	1 each
Weight:	5.1 lbs.
New Pig Patent:	Pending
# per Pallet:	50
Composition:	18 oz PVC covering Polyethylene bladder Acrylic resin support
UNSPSC:	24101907

PLR517 Metric Equivalent

Dimensions:	18.4cm W x 111.8cm L x 10.2cm H
Weight:	2.3 kg

Technical Information

Warnings & Restrictions:

There are no known warnings and restrictions for this product.

Regulations and Compliance:

40 CFR 264.175 - Hazardous waste containment systems must be free of structural cracks or gaps, be designed to keep spilled liquids from remaining in contact with the container, prevent run-on and "have sufficient capacity to contain 10% of the volume of the containers, or the volume of the largest container, whichever is greater."

40 CFR 122.26 - When applying for a National Pollutant Discharge Elimination System (NPDES) permit, facilities must have a plan in place that describes actions, procedures, control techniques, management practices and equipment available to prevent illegal discharge of pollutants into waterways.

40 CFR 112.7 - SPCC planning requirements state that facilities subject to these regulations must have written plans in place discussing the products, countermeasures and procedures that are in place, or will be taken by the facility to prevent discharge of oil into waters of the United States.

Technical Documents:

(Available at newpig.com)

Product Data Sheet (PDS)



New Pig

By Phone:
1-855-493-HOGS

Online:
newpig.com

Email:
hothogs@newpig.com

One Pork Avenue • Tipton PA 16684-0304

© 2014 New Pig Corporation. All rights reserved.
PIG and the PIG logo are trademarks in the U.S. and other countries.

ITEM: PLR517 - Pg 2 of 2